

VOC Content Test Certificate

Tuesday January 31st, 2012

Manufacturer: Wet-Seal (PO Box 481, Coffs Harbor, NSW 2450)

Sample Description: Enviro-Coat DS 411

Date Tested: January 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Enviro-Coat DS 411</p>
<p>Architectural Sealant 250 grams per Litre as VOC content per material</p>	<p>32 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120119