

# VOC Content Test Certificate

Tuesday January 31<sup>st</sup>, 2012

Manufacturer: Wet-Seal (PO Box 481, Coffs Harbor, NSW 2450)

Sample Description: Enviro-Coat IS 511

Date Tested: January 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Enviro-Coat IS 511</b>
Architectural Sealant  250 grams per Litre as VOC content per material	<b>52 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV120119