

DAVCO TECHNICAL SERVICES REPORT

Date Conducted: November 2005 Reference: P1040

TESTED ON BEHALF OF:

Customer: Wet-seal
Address: 31 Newcastle Drive
TOORMINA NSW 2452
Contact Name: Robert Rath
Product Type & Description: Two waterproofing membranes: Wet-seal Fibre Coat (green colour with fibre) and Wet-seal 400 (no fibre) were supplied. Both had been pre prepared on boards and were tested as received.

TEST DETAILS:

Standard: AS4992

Tests Conducted:
Wet-seal Fibre Coat 28 days tensile adhesion.
7days /21 days immersed tensile adhesion
14 days / 14 days at 70°C tensile adhesion

Wet-seal 400 28 days tensile adhesion.
7days /21 days immersed tensile adhesion
(heat tests not conducted as insufficient sample provided)

RESULTS AND RECOMMENDATIONS:

Based on the results obtained F1 express and Tradeflex may be used with the Wet-seal Fibre Coat product and Tradeflex may be used with the Wet-seal 400.

DAVCO CONSTRUCTION PRODUCTS PTY LTD



Gary Schwarz
Technical Services Manager

The information in this report is based solely on the information and samples made available to Davco Construction Products at the time of writing. Compliance with the relevant standards is the responsibility of the Specifier, Installer and/or tile manufacturer. Although care has been taken to ensure the information in this document is correct no liability will be accepted for its use.