

VOC Content Test Certificate

Wednesday 27th November 2019

Supplier: Wet Seal Management Pty Ltd (PO Box 481, Coffs Harbour, NSW, 2450, Australia).

Sample Description: Enviro-coat WPM Internal IS 520

Date Tested: November 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.2-13.1.1B Green Star Interiors V1.2-12.1.1B	Enviro-coat WPM Internal IS 520
Acoustic sealants, architectural sealant, waterproofing membranes and sealant: 250 grams per Litre	66 grams per Litre as VOC content per material
<p><i>We hereby certify that Enviro-coat WPM Internal IS 520 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V1911063