

# VOC Content Test Certificate

Thursday December 4<sup>th</sup>, 2008

Manufacturer: Wet-seal (PO Box 481, Coffs Harbour NSW 2450)

Sample Description: Enviro-coat IS MR 508 internal membrane for wet areas

Date Tested: November 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Enviro-coat IS MR508</b>
Architectural Sealant 250 grams per Litre as VOC content material	<10 grams per Litre as VOC content material
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Enviro-coat IS MR508</b>
Architectural Sealant 250 grams per Litre as VOC content material	<10 grams per Litre as VOC content material



Dr. Vyt Garnys

PhD, BSc(Hons) AusIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0811-14